



Building Department

UNIVERSITY OF CENTRAL FLORIDA

When are Fire Alarm Audio/Video shunts required?

- In conference rooms under 735 square feet, that have NFPA 72 compliant fire strobes installed, an A/V Fire Alarm shunt is not required.
- In a classroom under 980 Square feet, that have NFPA 72 compliant fire strobes installed, an A/V Fire shunt is not required.
- All other classrooms and Conference rooms require A/V Fire Alarm shunts.